

Fulton School**Lead Level ug/L**

2nd Floor water fountain outside Room 219 (new wing)	1.6
1st Floor Kitchen Food Prep sink	1.7
1st Floor Nurses Office sink #1	3.4
Basement Room 13 sink	4.3
Basement water fountain outside Boys Bathroom	5.4
1st Floor Room 119 sink	9.6
1st Floor Nurses Office sink #2	10
Basement Room 12 sink	27
1st Floor water fountain in Lobby outside Gym	< 1.0
2nd Floor Room 205 sink	No Sample
1st Floor Room 119 water fountain	No Sample